

Dartistech

UNCONFINED COMPRESSION TEST RESULTS (ASTM D-2166)



Project: Sample Project

Project No: 45453334

Client: Sample Client

Location: Sample Location

BH: BH1

Moist mass of specimen (g): 389.44

Sample description:

Sample name: BH01/2

Moisture content (%): 17.00

Sandy clay

Sample depth(m): 2.00

Length of specimen L (cm): 12.00

USCS: SW-SC AASHTO: A-2-7

Diameter of specimen D (cm) 5.00

Tested by: Dartistech

Proving ring calibration factor: 1 div. (N): 3.360


Date tested:

Area A0 (cm²): 19.63

cu (kN/m²): 67.27

qu (kN/m²): 134.54

BH01/O/2.5



Dartistech

UNCONFINED COMPRESSION TEST RESULTS (ASTM D-2166)



Project: Sample Project

Project No: 45453334

Client: Sample Client

Location: Sample Location

BH: BH1

Moist mass of specimen (g): 394.65

Sample description:

Sample name: BH01/3

Moisture content (%): 17.00

Sandy clay

Sample depth(m): 3.00

Length of specimen L (cm): 12.00

USCS: SW-SC AASHTO: A-2-6

Diameter of specimen D (cm) 5.00

Tested by: Dartistech

Proving ring calibration factor: 1 div. (N): 3.300

Date tested:

Area A0 (cm²): 19.63

cu (kN/m²): 67.70

qu (kN/m²): 135.41

BH01/N/3.5

