

Dartistech

COMPACTION TEST RESULTS (ASTM D-698 , ASTM D-1557 , ASTM D-4718)



Project: Sample Project

Project No: 45453334

Client: Sample Client

Location: Sample Location

BH: BH1	Tested by: Dartistech	Volume of mold (ft^3): 0.03333	Sample description:
Sample name: BH01/2	Test date: 12/15/2022 12:00:00	Weight of hammer (lb): 5.50	Sandy clay
Sample depth(m): 2.00		Number of layers: 3	
Standard: ✓ Modified: ✗		Blows/layer: 25	

LL	PI	Moisture content	Passing No.40 (%)	Passing No.200 (%)	Specific Gravity	USCS	AASHTO
47.12	37.06	17.23	100.00	52.63	2.85	CL	A-7-6

Wopt(%): 10.92 yd(max): 120.97

